



**DEVON &
SOMERSET**
FIRE & RESCUE SERVICE

**Glenn Askew
Chief Fire Officer**

**Mrs Julie Smart
Police Licensing Officer
Torquay Police Station
South Street
Torquay
TQ2 5AH**

**Western Command
Devon South Group
Torquay Headquarters
Newton Road
Torquay
TQ2 7AD**

Your ref :
Our ref : BL207559/P
Website : www.dsfire.gov.uk

Date : 28 June 2018
Please ask for : Paul Farmer
Email : pfarmer@dsfire.gov.uk

Telephone : 01803 653700
Fax : 01803 653740
Direct Telephone : 01803 653734

Dear Madam

**Licensing Act 2003
Application for a Review of a Licence
Re: The Terrace Bar 12-14 The Terrace Torquay TQ1 1BN**

Thank you for your letter dated 20 June 2018 with a copy of an Application for a Review of the licence for the above premises.

The Fire and Rescue Authority have inspected the premises and have the following observations to make in respect of this matter.

In accordance with the requirements of the Regulatory Reform (Fire Safety) Order 2005 a suitable and sufficient fire risk assessment was not available.

Yours faithfully

A handwritten signature in black ink, appearing to read 'Paul Farmer', written over a light blue horizontal line.

**Paul Farmer
Business Safety Officer**