



KEY	
(H)	HEAT DETECTOR
(H) ^S	HEAT DETECTOR & SOUNDER
(V)	VOID DETECTOR
(P)	PANEL
(S)	SMOKE DETECTOR
(S) ^S	SMOKE DETECTOR & SOUNDER
(S) ^{S-B}	SMOKE DETECTOR & SOUNDER & BEACON
(BG)	BREAK GLASS
△	FIRE EXTINGUISHER: E.G. 13A OR 34B. NUMBER INDICATES THE EXTINGUISHING CAPABILITY AND THE LETTER INDICATES THE CLASS OF FIRE THAT THE EXTINGUISHER IS SUITABLE FOR. FOR FURTHER INFORMATION SEE OUR GUIDANCE NOTE FSGN 8.
△	AQUEOUS FILM FORMING FOAM EXTINGUISHER.
△	CLASS F TYPE EXTINGUISHER.
△	FIRE BLANKET EXTINGUISHER.
△	CARBON DIOXIDE FIRE EXTINGUISHER.
△	DRY POWDER EXTINGUISHER.
△	FOAM FIRE EXTINGUISHER.
📺	CCTV
EM	MAINTAINED EMERGENCY LIGHT FITTING.
□	AREA FOR LICENSABLE ACTIVITIES
NOTES:	
SYSTEM DESIGNED TO BS 5839 PART 1: 2002.	
CATEGORY OF SYSTEM: L2	
SYSTEM DETAILS: CONVENTIONAL FIRE PANEL	
INSTALLATION METHOD: FP200G INSTALLED ON CABLE TRAY FIXED TO STRUCTURE.	
ALL FIRE FIGHTING EQUIPMENT SHOULD BE SO PLACED AS TO BE READILY AVAILABLE FOR USE. THEY SHOULD BE MOUNTED ON BRACKETS OR SUITABLE SHELVES IN CONSPICUOUS POSITIONS SO THAT THE CARRYING HANDLES OF THE LARGER HEAVIER EXTINGUISHERS ARE APPROXIMATELY 1.1M FROM THE FLOOR, AND THE HANDLES OF THE SMALLER FIRE EXTINGUISHERS ARE APPROXIMATELY 1.5M FROM THE FLOOR.	
ALL WALLS AND PARTITIONS TO BE MINIMUM HALF HOUR FIRE RESISTANT.	
EMERGENCY LIGHTING TO COMPLY WITH BS 5266 PART 1	
FIRE SAFETY RELATED SIGNS AND NOTICES TO COMPLY WITH BS 5499	
FIRE FIGHTING EQUIPMENT TO COMPLY WITH BS 5306.	
WALL AND CEILING LININGS ARE TO BE CLASS 1 SPREAD OF FLAME (AS DEFINED BY BS 476 PART 7) IN PUBLIC AREAS AND CLASS 0 IN ESCAPE ROUTES.	
UPHOLSTERED SEATING FURNITURE TO COMPLY WITH THE FOLLOWING: -IGNITION SOURCE (CIGARETTE TEST) AS SPECIFIED IN BS 5852 PART 2 FIRE TEST FOR FURNITURE. METHODS FOR TEST IGNITABILITY BY SMOKERS. -BS 5852 PART 2 FIRE TEST FOR FURNITURE METHODS OF TEST FOR THE IGNITABILITY OF UPHOLSTERED COMPOSITES FOR TESTING BY FLAME SOURCE. MINIMUM TEST TO BE CRIB IGNITION SOURCE 5.	
FABRICS THAT HAVE HAD A FLAME RETARDANT TREATMENT TO PASS THE WATER SOAK TEST AS DETAILED IN BS 5651. TEST CERTIFICATES TO BE SUBMITTED TO THE FIRE AUTHORITY.	
CURTAINS AND DRAPES TO SATISFY TYPE 8 PERFORMANCE REQUIREMENTS TO BE BS 5867 PART 2.	
ARTIFICIAL FOLIAGE AND DECORATIVE EFFECTS TO BE FIRE RETARDANT TO THE SATISFACTION OF THE AUTHORITY.	
PREMISES ADDRESS: Unit 4 Abbey Sands Torquay Devon	
THIS DRAWING IS UNDER COPYRIGHT AND NO PORTION SHOULD BE USED WITHOUT PRIOR CONSENT. USE FIGURED DIMENSIONS ONLY. ALL UNFIGURED DIMENSIONS SHOWN ARE TAKEN FROM FINISHED SURFACES. ALL DIMENSIONS AND LEVELS MUST BE CHECKED ON SITE, AND ANY INCONSISTENCIES REPORTED IMMEDIATELY TO BS PRIOR TO PUTTING WORKS IN HAND.	
REVISIONS:	
CODE:	DATE: DESCRIPTION:
B3 DESIGN JERS B3 Designers Ltd Studio 302, Metropolitan Wharf 70 Wharfedale Street London, E1W 3SS Tel: +44 (0)20 7729 8111 Fax: +44 (0)20 7729 8124	
PROJECT NO: 923	CLIENT/PROJECT: LAS IGUANAS TORQUAY
SITE ADDRESS: UNIT 4 ABBAY CRESCENT TORQUAY TQ2 5HB	
DATE: 26/11/14	DRAWN: OP
CHECKED: KJM	SCALE: 1:50 @ A1 1:100 @ A3
TITLE: LICENSING PLAN	
STATUS: FOR TENDER	
DWG. NO: 923-109-LIC	REV: Rev

1 LICENSING PLAN
1:50 @ A1 1:100 @ A3

